

FIREWORKS STAND REQUIREMENTS PRIOR TO OBTAINING PERMIT

PER NFPA 1

1. Storage units- not less than 1 hour rating with doors/openings of not less than 45 min. rating. (NFPA 1-65.11.4.4)
2. Fire Extinguishers- Min. (2) 2A rated with (1) being the pressurized water type and (1) dry chemical type. (NFPA 1-65.11.5.2.2)
 - Must be mounted not less than 3 ½ feet and not more than 5 feet off the ground.
 - If area is < 200 sq. ft., only (1) dry chemical type is required. (NFPA 1-65.11.5.2.2.1,2)
 - For permanent fireworks retail sales facilities, the maximum travel distance to reach an extinguisher shall not exceed 75 ft. (NFPA 1-65.11.5.2.3.1)
 - For temporary fireworks retail sales facilities, the maximum travel distance to reach an extinguisher shall not exceed 35 ft. (NFPA 1-65.11.5.2.3.2)
3. The area located within 30 ft. of a consumer fireworks retail sales facility shall be kept free of accumulated dry grass, dry brush, and combustible debris. (NFPA 1-65.11.6.2)
4. No motor vehicle or trailer used for the storage of consumer fireworks shall be parked within 10 ft. of the facility except when delivering, loading, or unloading merchandise. (NFPA 1-65.11.6.3)
5. Fireworks shall not be ignited, discharged, or otherwise used within 300 ft. of the facility. (NFPA 1-65.11.6.4.1)

At least one sign that reads the following in letters at least 4 in. high on a contrasting background shall be conspicuously posted on the exterior of each side of the facility: **NO FIREWORKS DISCHARGE WITHIN 300 FEET.** (NFPA 1-65.11.6.4.2)
6. Smoking shall not be permitted inside or within 50 ft. of the sales area. (NFPA 1-65.11.6.5.1)

At least one sign that reads as follows, in letters at least 2 in high on a contrasting background, shall be posted at each entrance or within 10 ft. of every aisle directly serving the sales area: **FIREWORKS - NO SMOKING.** (NFPA 1-65.11.6.5.2)
7. Aisle width shall have a minimum clearance of 48 in. (NFPA 1-65.11.8.5.1)

The required width of aisles shall be maintained unobstructed at all times the facility is occupied by the public. (NFPA 1-65.11.8.5.2)

Dead end aisles shall be prohibited. (NFPA 1-65.11.8.5.3.4)
8. Exit openings from tents shall have a clear opening width of not less than 44 in. (NFPA 1-65.11.8.6.2)
9. Exit signs shall be installed in compliance with NFPA 1-65.11.9.1.
10. Emergency lighting shall be provided and must comply with NFPA 1-65.11.9.2.
11. Electrical wiring shall be in accordance with Section 11.1 and shall comply with Article 305 of NFPA 70, National Electrical Code. (NFPA 1-65.11.11.1)